

Published 07.11.2022 Revision 2

#### **CONTENTS**

OVERVIEW	2
/ENTILATION CLASSIFICATION	3
CAULFIELD CAMPUS	
CLAYTON CAMPUS	
PARKVILLE CAMPUS	13
PENINSULA CAMPUS	15
MELBOURNE CBD	
ALFRED HOSPITAL	
MONASH MEDICAL CENTRE	



One important component of Monash's COVID Safe Plan is the provision of well-ventilated spaces to reduce the risk of COVID 19 transmission.

A comprehensive review of the ventilation systems supporting all University buildings and spaces has been conducted. The Australian Standard for building ventilation AS1668.2 was used to assess the suitability of the system to control for the transmission of COVID 19. The ventilation systems were categorised into 4 main types:

1. Fixed 100% outside air (verv low risk) 2. Variable outside air (very low risk)

3. Fixed outside air (low risk)

4. Local or no ventilation (moderate risk)

The vast majority of the University buildings and ventilation systems are in the first 3 categories and were assessed as very low to low risk for COVID 19 transmission. A number of buildings with category 4, 'local or no' ventilation, were identified and additional control strategies developed to further reduce the risk of COVID 19 transmission. This includes:

- a. removal of the space from the faculty or central teaching schedule.
- b. scheduling/taking group activities to other well-ventilated spaces or outside
- c. introduction of either conditioned or unconditioned forced outside air or forced extraction with make up air through internal wall louvres
- d. use of openable windows and doors to introduced outside air
- e. reduced occupancy limits
- f. use of portable HEPA filters

Please watch this video which further explains the ventilation systems at Monash and their role in controlling the risk of COVID 19 transmission.

The University's Ventilation strategy is part of the Monash COVID Safe Plan.

https://www.monash.edu/news/coronavirus-updates/covid-safe-plan



#### **VENTILATION CLASSIFICATION**

Buildings on our main campuses and sites in Australia have been classified based on the ventilation categories listed above. Please review this document to find the ventilation classification for your building.

Green	Buildings coded green have central ventilation systems that meet or exceed the standard for building ventilation AS1668.2 and provide sufficient outside air to ensure they are low risk for COVID-19 transmission. These are type 1, 2 or 3 systems.
Orange	Buildings coded orange have either local or no ventilation systems (type 4) and require additional COVID safe measures to be applied to reduce the risk of COVID-19 transmission.  Please contact Buildings and Property for details about your building and your specific area in the building.
Grey	Buildings coded grey have a combination of central and local ventilation systems and/or no ventilation systems.  Please contact Buildings and Property for details about your building and your specific area in the building.

#### Note:

If your building is not shown on the campus lists below please contact Buildings and Property at <u>buildings.property@monash.edu</u> for further information.



# **CAULFIELD CAMPUS**





# **CAULFIELD CAMPUS**

Map Index	Building ID	Building Name	Ventilation classification
A	501	Building A - Library	Meets or exceeds ventilation standard
В	502	Building B	Meets or exceeds ventilation standard
С	503	Building C	Meets or exceeds ventilation standard
D	504	Building D	Meets or exceeds ventilation standard
E	505	Building E	Meets or exceeds ventilation standard
F	506	Building F	Mixed ventilation - contact Buildings & Property for details
K	507	Building K	Meets or exceeds ventilation standard
N	508	Building N	Meets or exceeds ventilation standard
G	509	Building G	Meets or exceeds ventilation standard
Н	510	Building H	Meets or exceeds ventilation standard
S	518	Building S	Meets or exceeds ventilation standard
Т	520	Building T	Mixed ventilation - contact Buildings & Property for details
СС	538	Childcare Centre	Meets or exceeds ventilation standard



# **CLAYTON CAMPUS**





# **CLAYTON CAMPUS**

Map Index	Building ID	Building Name	Address	Ventilation classification
42 Sce	1	Monash Sport	42 Scenic Blvd	Meets or exceeds ventilation standard
28 Sce	1A	Hockey Pavillion	42 Scenic Blvd	Meets or exceeds ventilation standard
36 Sce	1B	Doug Ellis Swimming Pool	36 Scenic Blvd	Meets or exceeds ventilation standard
28 Sce	1C	Northern Pavilion	28 Scenic Blvd	Meets or exceeds ventilation standard
49 Sce	2	Robert Blackwood Hall	49 Scenic Blvd	Meets or exceeds ventilation standard
34 Exh	3C	Administration A	34 Exhibition Walk	Meets or exceeds ventilation standard
26 Spo	3D	Administration B	26 Sports Walk	Meets or exceeds ventilation standard
24 Spo	3E	Administration C	24 Sports Walk	Meets or exceeds ventilation standard
40 Exh	4	Sir Louis Matheson Library	40 Exhibition Walk	Meets or exceeds ventilation standard
57 Sce	5	Building 5	57 Scenic Blvd	Mixed ventilation - contact Buildings & Property for details
29 Anc	6	Education	29 Ancora Imparo Way	Mixed ventilation - contact Buildings & Property for details
48 Exh	7	Alexander Theatre	48 Exhibition Walk	Meets or exceeds ventilation standard
38 Exh	9	Religious Centre	38 Exhibition Walk	Meets or exceeds ventilation standard
21 Chn	10	Campus Centre	21 Chancellors Walk	Meets or exceeds ventilation standard
20 Chn	11	Menzies Building	20 Chancellors Walk	Meets or exceeds ventilation standard
15 Anc	12	David Derham Law Building	15 Ancora Imparo Way	Meets or exceeds ventilation standard
37 Rnf	13A	Medicine A	37 Rainforest Walk	Meets or exceeds ventilation standard



Map Index	Building ID	Building Name	Address	Ventilation classification
39 Rnf	13B	Medicine B	39 Rainforest Walk	Requires additional COVID safe measures
10 Chn	13C	Medicine C	10 Chancellors Walk	Requires additional COVID safe measures
35 Rnf	13D	Medicine D	35 Rainforest Walk	Mixed ventilation - contact Buildings & Property for details
9 Anc	13E	Medicine E	9 Ancora Imparo Way	Meets or exceeds ventilation standard
26 Inn	13F	Medicine F	26 Innovation Walk	Meets or exceeds ventilation standard
27 Rnf	15	Medical & Health Science	27 Rainforest Walk	Meets or exceeds ventilation standard
11 Chn	16	Biochemistry Laboratories	11 Chancellors Walk	Meets or exceeds ventilation standard
18 Inn	17	Biology	18 Innovation Walk	Meets or exceeds ventilation standard
25 Rnf	18	Biological Sciences	25 Rainforest Walk	Meets or exceeds ventilation standard
19 Rnf	19	Central Science	19 Rainforest Walk	Mixed ventilation - contact Buildings & Property for details
22 Rnf	20	Building 20	22 Rainforest Walk	Meets or exceeds ventilation standard
21 Rnf	21	Biological Sciences lecture theatres	21 Rainforest Walk	Meets or exceeds ventilation standard
23 Rnf	22	First Year Biology	23 Rainforest Walk	Meets or exceeds ventilation standard
17 Rnf	23	Senior Chemistry	17 Rainforest Walk	Meets or exceeds ventilation standard
15 Rnf	24	Western Science Lecture Theatre	15 Rainforest Walk	Meets or exceeds ventilation standard
16 Rnf	25	Eastern Science Lecture Theatre	16 Rainforest Walk	Meets or exceeds ventilation standard
14 Rnf	26	Information Technology & Faculty of Science	14 Rainforest Walk	Meets or exceeds ventilation standard
10 Col	27	Senior Physics	10 College Walk	Meets or exceeds ventilation standard
9 Rnf	28	Mathematics & EAE	9 Rainforest Walk	Mixed ventilation - contact Buildings & Property for details



Map Index	Building ID	Building Name	Address	Ventilation classification
11 Rnf	29	Northern Science Lecture	11 Rainforest Walk	Meets or exceeds ventilation standard
13 Col	30	Hargrave-Andrew Library	13 College Walk	Meets or exceeds ventilation standard
17 Col	31	Engineering 31	17 College Walk	Mixed ventilation - contact Buildings & Property for details
21 Col	32	Engineering Lecture Theatre	21 College Walk	Meets or exceeds ventilation standard
19 Col	33	Engineering 33	19 College Walk	Mixed ventilation - contact Buildings & Property for details
16 All	35	Engineering 35	16 Alliance Lane	Requires additional COVID safe measures
18 All	36	Engineering 36	18 Alliance Lane	Mixed ventilation - contact Buildings & Property for details
17 All	37	Engineering 37	17 Alliance Lane	Meets or exceeds ventilation standard
26 Res	40	Buildings & Property 40	26 Research Way	Meets or exceeds ventilation standard
13 Sce	41A	Building 41A	13 Scenic Blvd	Meets or exceeds ventilation standard
13 Sce	41B	Building 41B	13 Scenic Blvd	Meets or exceeds ventilation standard
13 Sce	41C	Building 41C	13 Scenic Blvd	Meets or exceeds ventilation standard
13 Sce	41D	Building 41D	13 Scenic Blvd	Meets or exceeds ventilation standard
13 Sce	41E	Building 41E	13 Scenic Blvd	Meets or exceeds ventilation standard
13 Sce	41F	Building 41F	13 Scenic Blvd	Meets or exceeds ventilation standard
13 Sce	41G	Building 41G	13 Scenic Blvd	Meets or exceeds ventilation standard
52 Col	42	JMR Environmental Labs	52 College Walk	Meets or exceeds ventilation standard
54 Col	42A	Plant Science Complex	54 College Walk	Meets or exceeds ventilation standard
50 Col	42C	JMR Education Centre	50 College Walk	Meets or exceeds ventilation standard



Map Index	Building ID	Building Name	Address	Ventilation classification
63 Col	43	Richardson Hall	63 College Walk	Requires additional COVID safe measures
61 Col	44	Roberts Hall	61 College Walk	Requires additional COVID safe measures
62 Col	45	Farrer Hall	62 College Walk	Requires additional COVID safe measures
60 Col	46	Howitt Hall	60 College Walk	Requires additional COVID safe measures
58 Col	47	MRS admin & amenities	58 College Walk	Requires additional COVID safe measures
56 Col	48	Deakin Hall	56 College Walk	Requires additional COVID safe measures
52 Anc	49	South-Eastern Flats	52 Ancora Imparo Way	Requires additional COVID safe measures
32 Exh	50	Monash University Club	32 Exhibition Walk	Meets or exceeds ventilation standard
101 Norm	52	Normanby House	101 Normanby	Requires additional COVID safe measures
101A Norm	52A	Normanby House - Research Annexe Shed	101A Normanby	Requires additional COVID safe measures
12 Inn	53	Institute of Vector-Borne Disease 12 Innovation Walk		Meets or exceeds ventilation standard
12 Anc	54	Japanese Study Centre	12 Ancora Imparo Way	Requires additional COVID safe measures
30 Res	56	Buildings & Property 56	30 Research Way	Meets or exceeds ventilation standard
15 All	59	Australian Pulp and Paper	15 Alliance Lane	Mixed ventilation - contact Buildings & Property for details
23 Col	60	Engineering 60	23 College Walk	Mixed ventilation - contact Buildings & Property for details
25 Exh	63	Faculty of Information Technology 25 Exhibition Walk		Meets or exceeds ventilation standard
43 Rnf	64	Faculty of Medicine Offices	43 Rainforest Walk	Meets or exceeds ventilation standard
14 Anc	65	Monash House	14 Ancora Imparo Way	Meets or exceeds ventilation standard
44 Exh	67	Matheson Library Annexe	44 Exhibition Walk	Meets or exceeds ventilation standard




Map Index	Building ID	Building Name	Address	Ventilation classification
55 Sce	68	Performing Arts Centre	55 Scenic Blvd	Meets or exceeds ventilation standard
22 All	69	Engineering 69	22 Alliance Lane	Mixed ventilation - contact Buildings & Property for details
21 All	70	Monash University Accident Research Centre	21 Alliance Lane	Meets or exceeds ventilation standard
14 All	72	Engineering 72	14 Alliance Lane	Meets or exceeds ventilation standard
49 Rnf	73	Building 73	49 Rainforest Walk	Meets or exceeds ventilation standard
33 Inn	73P	Learning Village	33 Innovation Walk	Meets or exceeds ventilation standard
8 Sce	74	Monash Sustainability Institute	8 Scenic Blvd	Meets or exceeds ventilation standard
10Sce	74P	74P Portable	10 Scenic Boulevard	Meets or exceeds ventilation standard
15 Inn	75	STRIP1 - Monash Biotechnology	15 Innovation Walk	Meets or exceeds ventilation standard
19 lnn	76	STRIP2 - Biomedical Sciences 19 Innovation W		Meets or exceeds ventilation standard
23 Inn	77	STRIP3 - Biomedical Sciences 23 Innovation Walk		Meets or exceeds ventilation standard
7 Inn	79P	North-West Portables	7 Innovation Walk	Mixed ventilation - contact Buildings & Property for details
10 lnn	81	Monash Centre Electron Microscopy	10 Innovation Walk	Meets or exceeds ventilation standard
20 Res	82	New Horizons	20 Research Way	Meets or exceeds ventilation standard
56 How	83	Monash Community Family Co-operative	56 Howleys Rd	Requires additional COVID safe measures
44 Col	85A	Jackomos Hall 44 College Walk		Requires additional COVID safe measures
42 Col	85B	Briggs Hall	42 College Walk	Requires additional COVID safe measures
13 Rnf	86	Green Chemical Futures	13 Rainforest Walk	Meets or exceeds ventilation standard
38 Col	87	Turner Hall	38 College Walk	Requires additional COVID safe measures



Map Index	Building ID	Building Name	Address	Ventilation classification
27 Spo	88	Holman Hall	27 Sports Walk	Requires additional COVID safe measures
21 Spo	89	Campbell Hall	21 Sports Walk	Requires additional COVID safe measures
28 Spo	90	Logan Hall	28 Sports Walk	Requires additional COVID safe measures
19 Anc	92	Learning and Teaching Building	19 Ancora Imparo Way	Meets or exceeds ventilation standard
7 Anc	93	Biomedical Learning and Teaching (BLTB)	7 Ancora Imparo Way	Meets or exceeds ventilation standard
20 Exh	94	Woodside Building TEd 20 Exhibition Wal		Meets or exceeds ventilation standard
27 Chn	96	Chancellery	27 Chancellors Walk	Meets or exceeds ventilation standard



# **PARKVILLE CAMPUS**





# **PARKVILLE CAMPUS**

Map Index	Building ID	Building Name	Address	Ventilation classification
Sissons	401	Sissons Building	381 Royal Parade	Meets or exceeds ventilation standard
Scott	402	Scott Building	381 Royal Parade	Meets or exceeds ventilation standard
Manning	403	Manning Building	381 Royal Parade	Mixed ventilation - contact Buildings & Property for details
404	404	399 Royal Parade	399 Royal Parade	Meets or exceeds ventilation standard
407	407	407 Royal Parade	407 Royal Parade	Meets or exceeds ventilation standard



# PENINSULA CAMPUS





# PENINSULA CAMPUS

Map Index	Building ID	Building Name	Ventilation classification
Α	601	A Building	Meets or exceeds ventilation standard
GJ	602	George Jenkins Theatre	Meets or exceeds ventilation standard
В	603	B Building	Meets or exceeds ventilation standard
С	604	C Building	Meets or exceeds ventilation standard
D	605	D Building	Meets or exceeds ventilation standard
E	606	E Building	Meets or exceeds ventilation standard
S	607	Struan House (S)	Requires additional COVID safe measures
СС	614	Early Childhood Centre	Mixed ventilation - contact Buildings & Property for details
G	617	G Building	Meets or exceeds ventilation standard
F	619	F Building	Meets or exceeds ventilation standard
L	621	L Building - Library	Meets or exceeds ventilation standard
Н	622	H Building	Meets or exceeds ventilation standard
U	650	U Building	Meets or exceeds ventilation standard
W	651	Activity & Recreation Centre (MPARC)	Mixed ventilation - contact Buildings & Property for details
BP	652	B Portables	Meets or exceeds ventilation standard
AP	653	A Portables	Meets or exceeds ventilation standard
R	658	Gillies Hall	Meets or exceeds ventilation standard



# MELBOURNE CBD






# **MELBOURNE CBD**

Map Index	Building ID	Building Name	Ventilation classification
555 Lonsdale	273	555 Lonsdale St (Law)	Meets or exceeds ventilation standard
30 Collins	282	30 Collins St	Meets or exceeds ventilation standard
750 Collins	825	750 Collins St	Meets or exceeds ventilation standard



# ALFRED HOSPITAL





# ALFRED HOSPITAL

Map Index	Building ID	Building Name	Address	Ventilation classification
AMREP	AL247A	AMREP building	75 Commercial Road	Meets or exceeds ventilation standard
Burnet	AL247B	Alfred MacFarlane Burnet Centre	85-89 Commercial Road	Meets or exceeds ventilation standard
Baker	AL247C	Baker building	75 Commercial Road	Meets or exceeds ventilation standard
Alfred Centre	AL248	Alfred Centre	99 Commercial Road	Meets or exceeds ventilation standard
553 St Kilda	AL831	553 St Kilda Rd	553 St Kilda rd	Meets or exceeds ventilation standard



# MONASH MEDICAL CENTRE





# MONASH MEDICAL CENTRE

Map Index	Building ID	Building Name	Address	Ventilation classification
MMC	255	Monash Medical Centre (MMC)	246 Clayton Rd	Meets or exceeds ventilation standard
TRF	258	Translational Research Facility (TRF)	45 Kanooka Grove	Meets or exceeds ventilation standard
MIMR	261	Monash Institute of Medical Research	27-31 Wright Street	Meets or exceeds ventilation standard
MHTP	262	Monash Health Translation Precinct	43-51 Kanooka Grove	Meets or exceeds ventilation standard



#### Further information

Monash University Wellington Road Clayton, Victoria 3800 Australia

E: buildings.property@monash.edu

monash.edu/news/coronavirus-updates/covid-safe-plan